

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/09/2018
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 495318		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED R 08/23/2016	
NAME OF PROVIDER OR SUPPLIER BERRY HILL NURSING HOME				STREET ADDRESS, CITY, STATE, ZIP CODE 621 BERRY HILL ROAD SOUTH BOSTON, VA 24592			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	<p>INITIAL COMMENTS</p> <p>Construction Type: II(000)</p> <p>Building description: The building is a single story facility with a partial basement that houses the mechanical room, generator room, and storage. The residents do not access the basement and it is separated by 1-hour rated construction consisting of protected steel columns and beams, unprotected steel bar joists supporting the metal pan and concrete main floor. The resident level is exterior masonry walls supporting steel joists, a metal pan and built-up roof.</p> <p>Sprinkler Status: Fully sprinklered NFPA 13 systems supplied by municipal water.</p> <p>An unannounced Life Safety Code revisit to the standard survey conducted 08/03/16 was conducted on 08/23/16, in accordance with 42 Code of Federal Regulation, Part 483: Requirements for Long Term Care Facilities. The facility was surveyed for compliance using the LSC 2000 Health Existing regulations. The facility was in compliance with the Requirements for Participation Medicare and Medicaid. Corrected deficiencies are identified on the CMS-2567B.</p>			{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.